



Environmental and Laboratory Services

Dover Location:
90 1/2 West Blackwell St., Dover, NJ 07801
Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:
8A Railroad Ave, Marlboro, NJ 07746
Phone: (732) 308-3500, Fax (732) 308-3503

Date: June 09, 2022
Client: Lead Charter School
Address: 201 Bergen Street
Newark, NJ 07103

PWSID#:
Project Location: 201 Bergen Street

Analytical Results

Sample Matrix:	Drinking Water	Lab Sample Number:	220526018-001						
Sample Location:	1F Hall L	Customer Sample Number:							
Sampled By:	B. Ellmers								
Sample Date/Time:	5/31/2022 6:58								

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/3/2022	19:12	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220526018-002						
Sample Location:	1F Hall R	Customer Sample Number:							
Sampled By:	B. Ellmers								
Sample Date/Time:	5/31/2022 7:00								

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/3/2022	17:54	JGW	2	1

Lead Charter School

Sample Matrix:	Drinking Water	Lab Sample Number:	220526018-003
Sample Location:	Kitchen Sink	Customer Sample Number:	
Sampled By:	B. Ellmers		
Sample Date/Time:	5/31/2022 7:02		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	3.65	µg/L	15	6/3/2022	17:59	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220526018-004
Sample Location:	2F Hall L	Customer Sample Number:	
Sampled By:	B. Ellmers		
Sample Date/Time:	5/31/2022 7:06		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/3/2022	18:05	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220526018-005
Sample Location:	2F Hall R	Customer Sample Number:	
Sampled By:	B. Ellmers		
Sample Date/Time:	5/31/2022 7:07		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/3/2022	18:11	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220526018-006
Sample Location:	3F Hall L	Customer Sample Number:	
Sampled By:	B. Ellmers		
Sample Date/Time:	5/31/2022 7:09		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	11.4	µg/L	15	6/3/2022	18:16	JGW	2	1

Lead Charter School

Sample Matrix:	Drinking Water	Lab Sample Number:	220526018-007
Sample Location:	3F Hall R	Customer Sample Number:	
Sampled By:	B. Ellmers		
Sample Date/Time:	5/31/2022 7:10		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	6.36	µg/L	15	6/3/2022	18:22	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220526018-008
Sample Location:	3F Staff BR	Customer Sample Number:	
Sampled By:	B. Ellmers		
Sample Date/Time:	5/31/2022 7:12		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/3/2022	18:27	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220526018-009
Sample Location:	3F Nurse	Customer Sample Number:	
Sampled By:	B. Ellmers		
Sample Date/Time:	5/31/2022 7:14		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	8.03	µg/L	15	6/3/2022	18:33	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220526018-010
Sample Location:	Field Blank	Customer Sample Number:	
Sampled By:	B. Ellmers		
Sample Date/Time:	5/31/2022 6:59		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/3/2022	18:38	JGW	2	1

Lead Charter School

NJ Lab ID# 14013 (Dover)


NJ Lab ID# 13033 (Marlboro)

NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.

Any method followed by an asterisk (*) was analyzed by the Agra-Marlboro laboratory.

All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.



Susan VanVeen, Laboratory Manager

June 09, 2022



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

2205260
220526018

Customer Name: Lead Charter School	Report to: Samad Mobley	Agra Environmental Services	# Asc./HCl Vials pH:
Location:	973-393-4608	90 1/2 West Blackwell Street	# HCl Vials pH:
Address: 201 Bergen Street	smobley@leadcharterschool.org,	Dover, NJ 07801	# Na ₂ S ₂ O ₃ Cl ₂ :
Newark, NJ, 07103		Phone: (973) 989-0010	# 10 HNO ₃ 220526018 pH: 22
Customer Contact: Samad Mobley		Fax: (973) 989-0156	# H ₂ SO ₄ pH:
Phone: Work/Cell 862-772-1724 / 973-393-4608			# NaOH pH:
			# unpreserved
			# other
			# other

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake Page 1 of 1

Project: 201 Bergen St 1st Draw	Collection	PWSID#					for laboratory use only	Field Analysis			
Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl ₂ or PO ₄
220526018-001	1F Hall L	5/31/22	0658	X		DW	1	HNO3	Lead-1st Draw		
220526018-002	1F Hall R		0700	X		DW	1	HNO3	Lead-1st Draw		
220526018-003	Kitchen Sink		0702	X		DW	1	HNO3	Lead-1st Draw		
220526018-004	2nd F Hall L		0704	X		DW	1	HNO3	Lead-1st Draw		
220526018-005	2F Hall R		0707	X		DW	1	HNO3	Lead-1st Draw		
220526018-006	3F Hall L B.T. R		0709	X		DW	1	HNO3	Lead-1st Draw		
220526018-007	3F Hall R B.T. L		0710	X		DW	1	HNO3	Lead-1st Draw		
220526018-008	3F Staff BR		0712	X		DW	1	HNO3	Lead-1st Draw		
220526018-009	3F Nurse		0714	X		DW	1	HNO3	Lead-1st Draw		
220526018-010	Field Blank		0659	X		DW	1	HNO3	Lead-1st Draw		

Sampled By (name/company): B. Ellmers/Agra

Are these samples for compliance? (circle one): Yes or **No**

Indicate laboratory location where analysis request was performed

NJDEP Laboratory Certification (Dover, NJ) #14013

NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box): Standard NJ Reduced Other (Specify)

Cooler Temperature Upon Receipt at lab: N/A

Sample Custody Exchanges (Please use full legal signature)						Comments:	
Relinquished By: <u>[Signature]</u>	Date: 5/31/22	Time: 1042	Received By: <u>[Signature]</u>	Date: 5/31/22	Time: 1442	<u>3 F HALL NOT WORKING</u> <u>Water Run 5/29 1700</u>	
Relinquished By: <u>[Signature]</u>	Date: 6/1/22	Time: 1100	Received By: <u>[Signature]</u>	Date: 6/1/22	Time: 1220		
Relinquished By: <u>[Signature]</u>	Date:	Time:	Received By:	Date:	Time:		
Relinquished By:	Date:	Time:	Received By:	Date:	Time:		

Date Faxed _____ Invoice Number _____ Turbid@marlboro 6/1/22 SL

Is sample known to be hazardous? (circle one) Yes or No