



Environmental and Laboratory Services

Dover Location:
90 1/2 West Blackwell St., Dover, NJ 07801
Phone: (973) 989-0010, Fax (973) 989-0156

Marlboro Location:
8A Railroad Ave, Marlboro, NJ 07746
Phone: (732) 308-3500, Fax (732) 308-3503

Date: June 09, 2022
Client: Lead Charter School
Address: 201 Bergen Street
Newark, NJ 07103

PWSID#:
Project Location: 5 Central Ave

Analytical Results

Sample Matrix:	Drinking Water	Lab Sample Number:	220526019-001						
Sample Location:	Rm 130 Kitchen	Customer Sample Number:							
Sampled By:	B. Ellmers								
Sample Date/Time:	5/31/2022 7:31								

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/3/2022	18:44	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220526019-002						
Sample Location:	Rm 133 Kitchen	Customer Sample Number:							
Sampled By:	B. Ellmers								
Sample Date/Time:	5/31/2022 7:33								

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/3/2022	19:34	JGW	2	1

Lead Charter School

Sample Matrix:	Drinking Water	Lab Sample Number:	220526019-003
Sample Location:	Women's BR 1 L	Customer Sample Number:	
Sampled By:	B. Ellmers		
Sample Date/Time:	5/31/2022 7:35		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/3/2022	19:40	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220526019-004
Sample Location:	Men's BR 4	Customer Sample Number:	
Sampled By:	B. Ellmers		
Sample Date/Time:	5/31/2022 7:37		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/3/2022	19:45	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220526019-005
Sample Location:	Men's BR 6	Customer Sample Number:	
Sampled By:	B. Ellmers		
Sample Date/Time:	5/31/2022 7:47		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/3/2022	19:51	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220526019-006
Sample Location:	Men's BR 2	Customer Sample Number:	
Sampled By:	B. Ellmers		
Sample Date/Time:	5/31/2022 7:39		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/3/2022	19:56	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220526019-007							
Sample Location: Women's BR 3		Customer Sample Number:							
Sampled By: B. Ellmers									
Sample Date/Time: 5/31/2022 7:41									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/3/2022	20:02	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220526019-008							
Sample Location: 1st Fl Utility Sink		Customer Sample Number:							
Sampled By: B. Ellmers									
Sample Date/Time: 5/31/2022 7:44									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/3/2022	20:07	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220526019-009							
Sample Location: Women's BR 5		Customer Sample Number:							
Sampled By: B. Ellmers									
Sample Date/Time: 5/31/2022 7:49									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/3/2022	20:13	JGW	2	1

Sample Matrix: Drinking Water		Lab Sample Number: 220526019-010							
Sample Location: Women's BR 1 R		Customer Sample Number:							
Sampled By: B. Ellmers									
Sample Date/Time: 5/31/2022 7:36									
Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/3/2022	20:35	JGW	2	1

Sample Matrix:	Drinking Water	Lab Sample Number:	220526019-011
Sample Location:	Field Blank	Customer Sample Number:	
Sampled By:	B. Ellmers		
Sample Date/Time:	5/31/2022 7:31		

Parameters	Method	Results	Units	NJDEP Limit	Date Analyzed	Time Analyzed	Analyst	Reporting Limit	Dilution Factor
Lead-1st Draw	SM3113B	< 2.00	µg/L	15	6/3/2022	20:41	JGW	2	1

NJ Lab ID# 14013 (Dover)
 NJ Lab ID# 13033 (Marlboro)

NJDEP Limit for free and/or total chlorine does not apply to non-chlorinated samples.
 Any method followed by an asterisk (*) was analyzed by the Agra-Marlboro laboratory.
 All other methods, unless otherwise specified, were analyzed by the Agra-Dover laboratory.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen
 Susan VanVeen, Laboratory Manager

June 09, 2022



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

2205260
220526019

Customer Name: Lead Charter School
 Location:
 Address: 201 Bergen Street
 Newark, NJ, 07103
 Customer Contact: Samad Mobley
 Phone: Work/Cell 862-772-1724 / 973-393-4608

Report to: Samad Mobley
 973-393-4608
 smobley@leadcharterschool.org,

Agra Environmental Services
 90 1/2 West Blackwell Street
 Dover, NJ 07801
 Phone: (973) 989-0010
 Fax: (973) 989-0156

Asc./HCl Vials pH:
 # HCl Vials pH:
 # Na₂S₂O₃ Cl₂:
 # 11 HNO₃ 250ml pH: ✓
 # H₂SO₄ pH:
 # NaOH pH:
 # unpreserved
 # other
 # other

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake

Project: 571 Central Ave 1st Draw

Collection PWSID#

for laboratory use only

Field Analysis

Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl ₂ or PO ₄
220526019-001	Rm 130 Kitchen	5/31/22	0731	X		DW	1	HNO3	Lead-1st Draw		
220526019-002	Rm 133 Kitchen		0733	X		DW	1	HNO3	Lead-1st Draw		
220526019-003	Women's BR 1 L		0735	X		DW	1	HNO3	Lead-1st Draw		
220526019-004	Men's BR 4		0737	X		DW	1	HNO3	Lead-1st Draw		
220526019-005	Men's BR 6		0747	X		DW	1	HNO3	Lead-1st Draw		
220526019-006	Men's BR 2		0739	X		DW	1	HNO3	Lead-1st Draw		
220526019-007	Women's BR 3		0741	X		DW	1	HNO3	Lead-1st Draw		
220526019-008	1st Fl Utility Sink		0744	X		DW	1	HNO3	Lead-1st Draw		
220526019-009	Women's BR 5		0748	X		DW	1	HNO3	Lead-1st Draw		
220526019-010	Women's BR 1 R		0736	X		DW	1	HNO3	Lead-1st Draw		

Sampled By (name/company):

B. Ellman

Are these samples for compliance? (circle one): Yes or **No**

Indicate laboratory location where analysis request was performed

NJDEP Laboratory Certification (Dover, NJ) #14013
 NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box):
 Standard NJ Reduced Other (Specify)

Cooler Temperature Upon Receipt at lab:

N/A

Sample Custody Exchanges (Please use full legal signature)

Relinquished By:	Date: 5/31/22	Time: 1042	Received By:	Date: 5/31/22	Time: 1042
Relinquished By:	Date: 6/2/22	Time: 1200	Received By:	Date: 6/2/22	Time: 1220
Relinquished By:	Date:	Time:	Received By:	Date:	Time:
Relinquished By:	Date:	Time:	Received By:	Date:	Time:

Comments: WATER? LAST ROW
 5/29 1700
 Turned @ Marlboro 6/1/22 SL

Date Faxed _____
 Invoice Number _____

Is sample known to be hazardous? (circle one)
 Yes or No



CHAIN OF CUSTODY / SAMPLE ANALYSIS REQUEST

2205260
220526019

Customer Name: Lead Charter School	Report to: Samad Mobley	Agra Environmental Services	# Asc./HCl Vials pH: _____
Location:	973-393-4608	90 1/2 West Blackwell Street	# HCl Vials pH: _____
Address: 201 Bergen Street	smobley@leadcharterschool.org,	Dover, NJ 07801	# Na ₂ S ₂ O ₃ Cl ₂ : _____
Newark, NJ, 07103		Phone: (973) 989-0010	# HNO ₃ pH: _____
Customer Contact: Samad Mobley		Fax: (973) 989-0156	# H ₂ SO ₄ pH: _____
Phone: Work/Cell 862-772-1724 / 973-393-4608			# NaOH pH: _____
			# unpreserved _____
			# other _____
			# other _____

Matrix Abbreviations: DW - Drinking water GW - Ground Water RAW-GW - DW RAW GW WW/NPW - Wastewater SL - Sludge P - Pool L - Lake Page 2 of 2

Project: 571 Central Ave 1st Draw		Collection	PWSID#				for laboratory use only	Field Analysis			
Sample ID	Location	Date	Time	Grab	Comp	Matrix	# of Bottles	Preservative	ANALYSIS REQUESTED	pH / Temp	Cl ₂ or PO ₄
220526019-011	Field Blank	5/31/22	0731	X		DW	1	HNO3	Lead-1st Draw		

Sampled By (name/company): B. Ellmers/Agra Are these samples for compliance? (circle one): Yes or No

NJDEP Laboratory Certification (Dover, NJ) #14013
 NJDEP Laboratory Certification (Marlboro, NJ) #13033

Reporting Requirements (Check Box): Standard NJ Reduced Other (Specify)

Indicate laboratory location where analysis request was performed: _____

Cooler Temperature Upon Receipt at lab: 3.1°C

Sample Custody Exchanges (Please use full legal signature)

Relinquished By: <u>[Signature]</u>	Date: <u>5/31/22</u>	Time: <u>1042</u>	Received By: <u>[Signature]</u>	Date: <u>5/31/22</u>	Time: <u>1042</u>	Comments: <u>Turbid @ Marlboro 6/1/22 x</u>
Relinquished By: <u>[Signature]</u>	Date: <u>6/1/22</u>	Time: <u>1200</u>	Received By: <u>[Signature]</u>	Date: <u>6/1/22</u>	Time: <u>1220</u>	
Relinquished By: _____	Date: _____	Time: _____	Received By: _____	Date: _____	Time: _____	
Relinquished By: _____	Date: _____	Time: _____	Received By: _____	Date: _____	Time: _____	

Date Faxed _____
 Invoice Number _____

Is sample known to be hazardous? (circle one)
 Yes or No